

# Certificate



Intertek

for European Product Safety

Reference No. 1309485

## Fan for mounting in ventilating duct

Type designation KVKE\*\*\*\*

Certificate holder **Systemair AB**  
Industrivägen 3  
739 30 Skinnskatteberg  
SWEDEN

The product complies with the standard(s) EN 60335-1:2012  
EN 60335-2-80:2003+A1+A2  
EN 62233:2008

Date of expiry 4 September 2019

EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.*


Technical data

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

  
\_\_\_\_\_  
Niclas Lood

Date 4 September 2014  
Page 1 of 3



Intertek  
Appendix

Reference No. 1309485

Type designation	KVKE 125
Rated voltage (V)	230
Rated power (W)	55
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 160
Rated voltage (V)	230
Rated power (W)	97
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 200
Rated voltage (V)	230
Rated power (W)	153
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 250 M
Rated voltage (V)	230
Rated power (W)	185
Frequency (Hz)	50
Class	I
IP-Class	44

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*

**Intertek  
Appendix**

Reference No. 1309485

Type designation	KVKE 250 L
Rated voltage (V)	230
Rated power (W)	257
Frequency (Hz)	50
Class	I
IP-Class	44


Type designation	KVKE 315 M
Rated voltage (V)	230
Rated power (W)	284
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 315 L
Rated voltage (V)	230
Rated power (W)	497
Frequency (Hz)	50
Class	I
IP-Class	44

Manufacturing site(s)	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
-----------------------	---

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed

  
\_\_\_\_\_  
Niclas Lood

Date 4 September 2014

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*