

Certificate




Reference No. 706983

Fan for mounting in ventilating duct

Type designation	KVKE ****
Certificate holder	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
The product complies with the standard(s)	EN 60335-1:2002+A11+A1+A12+A2 EN 60335-2-80:2003+A1 EN 50366:2003+A1
Date of expiry	17 June 2013
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Erik Wallerfelt	Date	17 June 2008 Page 1 of 4

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

UHL



Appendix

Reference No. 706983

Technical data

Type designation	KVKE 125
Rated voltage (V)	230
Rated power (W)	55
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 160
Rated voltage (V)	230
Rated power (W)	97
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 200
Rated voltage (V)	230
Rated power (W)	153
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 250 M
Rated voltage (V)	230
Rated power (W)	185
Frequency (Hz)	50
Class	I
IP-Class	44

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Appendix

Reference No. 706983

Type designation	KVKE 250 L
Rated voltage (V)	230
Rated power (W)	257
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 315 M
Rated voltage (V)	230
Rated power (W)	284
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	KVKE 315 L
Rated voltage (V)	230
Rated power (W)	497
Frequency (Hz)	50
Class	I
IP-Class	44

Manufacturing site(s)	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
-----------------------	---

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Appendix

Reference No. 706983

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the products according to the Low Voltage Directive 2006/95/EC.

The product is not evaluated with respect to countries with a mains voltage of 230 V + 10 %.

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed  *Date* 17 June 2008
Erik Wallerfelt

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.